

KENTUCKY RIVER ADD PLANNING AREA

Water Losses

Unaccounted-for water losses (difference between water withdrawn and water sold) were highest for those systems most susceptible to drought. The figures shown in are based on the best available.

Water Supplier	Percent Unaccounted-for Water
Whitesburg Municipal Water	26
Fleming-Neon Water Company	23
Jenkins Water Works	74
Hindman Municipal Water Works	7.6
Hazard Water Department	37
Vicco Water System	45
Jackson Municipal Water Works	12
Hyden-Leslie County Water District	34
Booneville Water & Sewer	14
Beattyville Water Works	7

Percent unaccounted-for water by system.